

## IEA 4E SSL Annex Interlaboratory Comparison of Measurements of Temporal Light Modulation – Plan

Steve Coyne<sup>1</sup> and Yoshi Ohno<sup>2</sup>

<sup>1</sup> Light Naturally, Brisbane, Australia

<sup>2</sup> National Institute of Standards and Technology, Gaithersburg, USA



---

# Background



Solid State Lighting Annex  
Energy Efficient End-use Equipment  
International Energy Agency

# International Energy Agency

## 4E – Energy Efficient End-use Equipment

### Solid State Lighting Annex

#### Members (Country governments)

Australia, Denmark, France, Republic of Korea, Sweden, United Kingdom (Oct. 2022)

**Objective: Promote solid-state lighting worldwide for energy saving and quality assurance of products**

Phase I (2010 – 2014)

Phase II (2014 – 2019)


Phase III (2019 – 2024)

<http://ssl.iea-4e.org/>

#### Current Tasks

- Task 1. Human Centric Lighting – Health and Comfort
- Task 2. Lifetime of SSL Lamps and Luminaires
- Task 3. Lighting and Environment
- **Task 4. Interlaboratory Comparison of Temporal Light Modulation**
- Task 5. Test Methods and Performance Metrics
- Task 6. Quality and Performance Tiers
- Task 7. Smart Solid State Lighting
- Task 8. Database of SSL Products Performance

#### 20 technical reports published since 2012



IEA Technology Collaboration Programme  
on Energy Efficient End-Use Equipment



# Background 1 – TLM requirements for products in regulatory programs

- **EU Ecodesign regulation** lighting omnibus has  $P_{st}^{LM}$  and SVM requirements. (Dec. 2019, effective Sept 2021)
  - Proposal to be adopted by **Australia and New Zealand**
- **US Energy Star** requires reporting of nominated TLM metrics for dimmable lamps under dimmed conditions (2015)
- **California Energy Commission** has TLM limits for dimmable lighting products under dimmed conditions (2016)
- UN Environment **U4E Model Regulations** for lamps has  $P_{st}^{LM}$  requirements. (adopted in **Pakistan** 2021, **Tunisia, Bolivia**). Expected to also follow EU with inclusion of SVM.
- Other countries (in **Southern & Eastern Africa, Central & South America**) supported by **CLASP** activities
- Proposed adoption of IEC TR 61547-1 and IEC TR 63158 by **China**



---

# The Program


# Interlaboratory Comparisons of Measurements of TLM (IC 2022)

## Objectives

- Investigate the level of agreement in measurements of temporal light modulation (TLM) quantities by laboratories worldwide, focusing on measurements of:
  - **Short-term flicker index ( $P_{st}^{LM}$ )** defined in IEC TR 61547-1
  - **Stroboscopic effect visibility measure (SVM)** defined in IEC TR 63158.
- Provide proficiency test for measurement of  $P_{st}^{LM}$  and SVM for accreditation programs
- Promote a harmonised and accurate measurement of TLM quantities globally.


# Scheme of IC 2022

## Nucleus Labs Comparison




Scheme 1

## IC 2022 Measurement Rounds




OR

## Nucleus Labs Comparison



Scheme 2

## IC 2022 Measurement Rounds



# Cooperation with EMPIR MetTLM

**EMPIR: European Metrology Program for Innovation and Research**

**MetTLM: Metrology for Temporal Light Modulation**

- MetTLM leader: Paul Dekker (VSL, Netherlands)
- Project duration - May 2021 to May 2024
- DTU (SSL Annex Expert member) is a member of MetTLM
- Invitation to IEA 4E-SSL Annex for membership to project stakeholder committee
  - Possibilities to discuss with the project partners regarding matters related to TLM
  - Options to raise questions and influence the direction of the project
  - Invitations to stakeholder meetings held during the project
  - Optional offer to be listed as stakeholder on the project website
  - No formal obligations
- **LETTER OF AGREEMENT** signed on Nov. 16, 2022 - Steve Coyne is liaison rep for Annex



# Contact with China

- May 2022.... Email communication with Wei Zhang, NLTC. She recommends two organizations to run regional comparisons in China:
  1. **National Lighting Test Centre (NLTC).**
  2. **CQC standard (Shanghai) testing technology Co. Ltd.** It is a CNAS recognized testing laboratory controlled by China Certification Centre (CQC). CQC is also interested in the comparison since this may helping to build reliable/comparable results from different laboratories towards certification.
  3. In addition, there will be support from **Beijing Lighting Research Institute (BLRI)**, the brother organization of NLTC. BLRI is the secretariat of China national standardization committee on lighting (SAC/TC 224), and also mirror to IEC/TC 34 (The publication organization of IEC TR 61547-1 and IEC TR 63158). BLRI is now adopting IEC TR 61547-1 and IEC TR 63158 as China national standards, experimental verification (testing by different laboratories) can be expected.
- **China Exco representative is from CNIS.** Communication from SSL Annex to CNIS received reply offering Intertek lab to run China's regional comparisons
- Communication with NLTC just before Chinese New Year revealed nothing resolved yet.
- **Task 4 Recommends that China run a separate interlab comparison that can be linked to IC 2022. IC2022 will provide protocol documents to China to replicate IC thereby allowing the linking of results.**

# Interlaboratory Comparisons of Measurements of TLM (IC 2022)

## Outline

- **Instruments:** commercially available or custom-made instruments/systems to measure light waveforms, P<sub>st</sub>LM and SVM of light sources, meeting the requirements in CIE TN 012.
- **Artefacts:** 4 LED lamps + TLM simulator source
- **Measurement quantities:**
  - P<sub>st</sub><sup>LM</sup> and SVM, light waveforms
- **Test methods:**
  - IEC TR 63158 (for SVM)
  - IEC TR 61547-1 (for P<sub>st</sub><sup>LM</sup>)
  - CIE TN 012:2021 (for data sampling and measurement)
- **Target participants:** Testing labs, lighting manufacturers, instrument manufacturers, research laboratories

# Comparison Artefacts (tentative)

Four LED lamp artefacts (ART-1 to ART-4) and one TLM generator source (ART-5) are considered.

The LED lamps will have a bulb shape of A60 with E27 screw base, rated for 230 V AC, 50 Hz, with the following ranges of TLM waveform:

## ART-1 to ART-4 (The values are tentative.)

Artefact	PstLM (range)	SVM (range)
Art-1	Low; < 0.1	Low; < 0.1
Art-2	Low; < 0.2	High; 0.4 – 0.9
Art-3	High; > 1.0	Low; < 0.2
Art-4 complex waveform	> 0.5	> 2.0



The LED lamps will be operated under the conditions (ambient temperature, stabilization, operating position) specified in CIE S 025.

# Measurement Quantities and Reported Information

	Comparison Quantities	Symbol
1	Short-term flicker index	$P_{st}^{LM}$
2	Stroboscopic effect visibility measure	$M_{VS}$

Uncertainties (k=2) of each quantity are also required (though results without uncertainties would also be accepted).

	Optional quantities for comparison	Symbol
15	Percent Flicker (PF)	$M_A$
16	Flicker Index (FI)	$I_F$
17	Perceptual Modulation	$M_p$
18	California Energy Commission (For dimmable products at levels of 100%, 20% and minimum fraction of light output)	
	Percent amplitude modulation unfiltered (same as entry 3 above)	$M_A$
	Percent amplitude modulation with < 1,000 Hz cut-off	$M_{A, <1\text{ kHz}}$
	Percent amplitude modulation with < 400 Hz cut-off	$M_{A, <400\text{ Hz}}$
	Percent amplitude modulation with < 200 Hz cut-off	$M_{A, <200\text{ Hz}}$
	Percent amplitude modulation with < 90 Hz cut-off	$M_{A, <90\text{ Hz}}$
	Percent amplitude modulation with < 40 Hz cut-off	$M_{A, <40\text{ Hz}}$

	Other results reported
3	Supply voltage measured (and uncertainty)
4	RMS current of the lamp (and uncertainty)
5	Active power of the lamp (and uncertainty)
6	Sampling rate (kHz) (PstLM / SVM)
7	Calculation duration (s) (PstLM / SVM)
8	Optical waveform data (Instructions in Results Report form)
9	Dominant frequency (optional)
10	Modulation depth (optional)
11	Ambient temperature (and uncertainty)

	Other information reported
12	TLM measurement device used
13	Optical input method (sphere or bench)
14	Power supply used

# Data Analyses

## (1) Differences

$$x - X$$

$x$ : participants' result  
 $X$ : reference value

for each participant and for each artefact, for  $P_{st}^{LM}$  and  $M_{VS}$ ,

SDPA - Standard Deviation for Proficiency Assessment

## (2) z' score

For proficiency test purposes, z' score (ISO 13528) is calculated by

$$z' = \frac{x - X}{\sqrt{\hat{\sigma}^2 + u_X^2 + u_{drift}^2}}$$

Where

$\hat{\sigma}$ : SDPA value

$u_X$ : standard uncertainty of the reference value

$u_{drift}$ : standard uncertainty for artefact drift calculated by

$$u_{drift} = \frac{0.8 \cdot \hat{\sigma}}{2\sqrt{3}}$$

## (3) En number

For proficiency test purposes, En number (ISO/IEC 17043) is calculated by

$$E_n = \frac{x - X}{\sqrt{U_{lab}^2 + U_{ref}^2}}$$

where

$U_{lab}$  expanded uncertainty ( $k=2$ ) of a participant's result

$U_{ref}$  expanded uncertainty ( $k=2$ ) of the reference value.

# Comparison Reports

---

**(1) IC 2022 Technical Protocol**

**(2) Nucleus Laboratories Comparison Report** – issued after completion of the Nucleus Laboratories Comparison

**(3) Individual Test Reports (ITR)** – issued to each participant after each measurement round is completed. The ITRs may be used for a proficiency test in laboratory accreditation programs that recognize IC 2022.

**(4) Final Report** – issued, presenting the results comparing measurements of all participants in an anonymous manner. The report will provide results for each artefact type and each of the measurement quantities, and discuss problems observed and considerations made in the results.




---

# Activities: Ascertain Demand/Interest in IC 2022

# Pre-announcement and EOI on IC 2022

July 2022 - Pre-announcement distributed by email to our global mailing list



## Points

- SSL Annex is assessing market interest for an interlaboratory comparison of TLM
- Comparison quantities;  $P_{st}^{LM}$  and SVM
- IEC TR 61547-1, IEC TR 631585 and CIE TN 012:2021 as the test methods
- Technical study as well as serving as proficiency test
- Fee: €2400 to €3800 per lab
- Submit completed expression of interest form

### Expression of Interest IEA 4E SSL Annex's 2022 Interlaboratory Comparison of Temporal Light Modulation Measurements (IC 2022)

Expression of Interest	
<b>Laboratory Details</b>	
Laboratory Name	
Country	
Physical Address	
General Phone Number	
<b>Representative Contact Details</b>	
Name	
Position	
Phone Number	
Email	
<b>Purpose of Participation in IC 2022</b>	
Proficiency Test	<input type="checkbox"/> Yes <input type="checkbox"/> No
Benchmarking	<input type="checkbox"/> Yes <input type="checkbox"/> No
Please return completed form to: <a href="mailto:ssl.annex@gmail.com">ssl.annex@gmail.com</a>	

## Received 21 responses

Europe: Denmark, Germany, France, Sweden, Slovenia

Africa: Uganda

Asia Pacific: Australia

South America: Brazil,

Central America: Costa Rica

- They are testing laboratories, instrument manufacturers, lighting manufacturers, universities and research institutes.
- Most of them are interested in PT
- **No labs from China, USA**



# Nucleus Laboratories

- Discussions with all member countries/laboratories
- Finalised:

## Operational Nucleus Laboratory:

### Korea Institute of Lighting and ICT (KILT)

- Coordinator: [Dr. Hee-Suk Jeong](#)
- Technical contact: [Jun-Seok Oh](#)

## Supporting Nucleus Laboratory

### Technical University of Denmark (DTU)

- Coordinator: [Carsten Dam-Hansen](#)
- Technical contact: [Carsten Dam-Hansen](#)

## Supporting Nucleus Laboratory

### National Institute of Standards and Technology (USA)

- Coordinator: [Dr. Yoshi Ohno](#)
- Technical contact: [Dr. Yoshi Ohno](#)

- Now in preparation for Nucleus Laboratory Comparison



---


# Activities: Consistency of test methods used by nucleus labs

## Capabilities of Nucleus Lab Equipment

---

- Need to understand the flexibility of measurement settings and hardware (especially low pass filter) for  $P_{st}^{LM}$  and SVM measurements

# DTU Measurement setup





# DTU Measurement setup

---

- Hardware:
  - Home constructed
  
- Software:
  - Matlab script for control and analysis

# KILT Measurement setup



# KILT Measurement Equipment Information

- Hardware:
  - Commercial



- Software:
  - Included

**UPRtek**

**MK350S Premium**

Handheld Spectrometer



	EVERFINE (Main)	UPRTEK (Sub)
1) Brand/model of your TLM measuring equipment (or home built – including specs of photometer head, I-V amplifier, digitizer)	LFA-3000	MK350S
2) Selection (range) of sampling rate (kHz) you can choose, and the sampling rate you normally use for PstLM and SVM	100k/sec	100k/sec
3) Selection (range) of acquisition duration (s), and the duration you normally use for PstLM and SVM	180s	n/a
4) If you use a low pass filter, its type (analog or digital) and cut-off frequency (kHz) and selections of frequencies if it is selectable	n/a	optional function
5) Optical geometry – photometric bench measuring one direction, or using integrating sphere?	Both possible	one direction
6) PstLM and SVM calculation software - name/version (or home built), if not inclusive in the TLM meter described above	Light Flicker Analyzer (v2.00.124)	uFlicker (v1.0.2.3)
7) Does KILT provide calibration service for TLM, in particular, PstLM and SVM? Or, it is for your research purpose? How long do you have experience measuring TLM?	KILT have been providing domestic certification and testing for lighting products since 2016 but doesn't provide calibration service for TLM.	


# KILT Measurement Equipment Information

## Test condition


Photometric Type: Illuminance(lx)      Test range: Range2      Sampling Mode: Software  
Samplerate: 100 kS/s      Sampling Time: 10.00 s      Frequency Cal.: Input

## Test Wave

Global Waveform(0-10.000s)



Local Waveform(0.000-0.100s)



## Test Result

<b>Avg(lx) :</b>	832.283	<b>Max(lx) :</b>	1.042 k	<b>Min(lx) :</b>	615.862
<b>Flicker Index:</b>	0.079	<b>Percent Flicker:</b>	25.302%	<b>Frequency:</b>	119.972 Hz




# KILT Measurement Equipment Information

## Test condition


Photometric Type: Illuminance(lx)    Test range: Range2    Sampling Mode: Software  
 Samplerate: 100 kS/s    Sampling Time: 10.00 s    Frequency Cal.: Input

## Test Wave

Global Waveform(0-10.000s)



Local Waveform(0.000-0.100s)



## Test Result


**Avg(lx) :** 832.283    **Max(lx) :** 1.042 k    **Min(lx) :** 615.862  
**Flicker Index:** 0.079    **Percent Flicker:** 25.302%    **Frequency:** 119.972 Hz

## Test condition


Photometric Type: Illuminance(lx)    Test range: Range2    Sampling Mode: Software  
 Samplerate: 100 kS/s    Sampling Time: 10.00 s

## Test Wave

Local Waveform(0.000-10.000s)





Relative Spectrum Waveform




## Test Result

**Avg(lx) :** 779.450    **Max(lx) :** 973.331    **Min(lx) :** 577.493  
**Frequency:** 119.971 Hz    **SVM:** 0.890    **Visibility:** Not Visible

# NIST Measurement Setup



Lamp mount to be modified for base-up



Sampling rate: 5 kHz to 500 kHz  
- normally 20 kHz~100 kHz

Sampling duration: 1 s to 180 s

Analog Filter unit (low-pass)

- Cut-off freq. 1 kHz, 3 kHz, 10 kHz
- Roll off 6dB/oct, 12 dB/oct

Digital filter: Butterworth low-pass filter

- Cut-off freq. 1 kHz to 10 kHz
- Roll off 6dB/oct(1), 12 dB/oct(2),...

# NIST's study on Measurement of P<sub>st</sub><sup>LM</sup> and SVM

Studied the effects of different measurement conditions on the results of P<sub>st</sub><sup>LM</sup> and SVM for 11 re

- Sa
- M
- Fi
- D




Fig. 5. P<sub>st</sub><sup>LM</sup> values for all the waveforms at durations varied from 20s to 180s filtered using 2<sup>nd</sup> order physical filter with cut-off frequency at 3 kHz, sampled at 50 kHz.

(red triangles) resampled at sampling rates varying from 5 kHz to 100 kHz.





Fig. 3

...s filtered using 2<sup>nd</sup> order physical filter with cut-off frequency at 3 kHz, sampled at 50 kHz.



---

# Activities: Drafting IC 2022 Technical Protocol



Solid State Lighting Annex:  
Interlaboratory Comparison 2022 (IC 2022) on  
Measurement of Temporal Light Modulation

Technical Protocol Draft (for Nucleus Lab Comparison)

Energy Efficient End-Use Equipment (4E)  
International Energy Agency

22 March 2023






---

# Activities: Identify Suitable Artefacts

# Artefact Identification - Range of $P_{st}^{LM}$ and SVM values of LED lamps

Pre-2020 procurement – Displayed results of lamps tested


2022 onwards – having difficulty identifying products with high SVM and/or  $P_{st}^{LM}$  values



# Art-1 (Low PstLM, Low SVM)

## Product Details



Brand	Crompton Lamps	
Model	GLS-ES-E27 A-Class Energy	
Description	LED filament	
Base Type	E27	
Wattage	3.8	watts
Lifetime		hours
CCT		K
CRI		
Lumens	806	lm
Efficacy (box)	212	lm/W








# Art-1 (Low PstLM, Low SVM)

## Stability





# Art-1 (Low PstLM, Low SVM)

## Stability



# Art-1 (Low PstLM, Low SVM)


## Reproducibility



# Art-2 (Low PstLM, Mid SVM)



## Product Details

Brand	CALEX Holland	
Model	Clear Spherical Bulb	
Description	Filament	
Base Type	E27	
Wattage	3.5	watts
Lifetime	15,000	hours
CCT	2700	K
CRI		
Lumens	350	lm
Efficacy (box)	100	lm/W






# Art-2 (Low PstLM, Mid SVM)

## Stability





# Art-2 (Low PstLM, Mid SVM)

## Stability



# Art-2 (Low PstLM, Mid SVM)

## Reproducibility



## Art-3 (High PstLM, Low SVM)

---


- Nothing found yet!



# Art-4 (Low PstLM, High SVM)



## Product Details

Brand	XG	
Model	XG-2512C 12W	
Description	Clear stick, corn COB	
Base Type	E27	
Wattage	12	watts
Lifetime	10,000	hours
CCT	6500	K
CRI	80	
Lumens	1200	lm
Efficacy (box)	100	lm/W






# Art-4 (Low PstLM, High SVM)

## Stability



# Art-4 (Low PstLM, High SVM)

## Stability



## Art-4 (**Low** PstLM, High SVM)


---

Reproducibility (**to be completed**)


# Art-4 (Low PstLM, High SVM)

## Product Details


Brand	Verbatim	
Model	65959	
Description	Frosted candle (dimnable)	
Base Type	E27	
Wattage	5	watts
Lifetime	15,000	hours
CCT	Warm white	
CRI		
Lumens	480	lm
Efficacy (box)	96	lm/W




Light Waveform



Spectral content - flicker region




Spectral content - stroboscopic region




# Art-4 (Low PstLM, High SVM)

## Stability



# Art-4 (Low PstLM, High SVM)

## Stability




# ART-5 (as Technical Study – tentative)

## TLM Generator Source: VISO Systems – Temporal Light Modulation Simulator “Labarazzi”



- Waveforms: Square, PWM, Sine, Triangle, Sawtooth
- Frequency range: 2 - 10,000 Hz
- Modulation: 1 – 100%
- Duty Cycle (PWM): 1 – 100%
- Programmable waveforms



## Waveforms to use (ideas)

- AC 60 Hz operation (120 Hz)
- Complex programmed waveform
- Some of the verification waveforms in IEC TR 63158

Table A.1 – Specification of the parameters of the verification waveforms


Verification waveform No.	Type of modulation	Modulation frequency $f_m$ Hz	Modulation depth $m_{ver}$	Reference value of the stroboscopic effect visibility measure $S_{F,3F}$
VW-sq1	Square pulse – Formula (A.10)	99	0,200 5	1,000
VW-sq2		100	0,201 2	1,000
VW-sq3		100	0,020 1	0,100
VW-sq4		100	0,804 8	4,000
VW-sq5		101	0,201 9	1,000
VW-sn1	Sinusoidal – Formula (A.11)	32	1,000 0	0,991
VW-sn2		100	0,256 3	1,000
VW-sn3		500	0,731 4	1,000
VW-sn4		1 900	0,999 7	1,000




# Stability of the TLM simulator output (preliminary test)

100 Hz optical square waveform with 50% modulation depth sampled at 20 kHz  
**(SVM = 2.4848)**

Stability of Waveform Modulation Depth





Stability of SVM Measurement




Statistical data of the stability (30 min to 60 min) of the data above

	<b>Mean (Relative to initial)</b>	<b>Std Dev (Relative to initial)</b>	<b>Uncertainty (k=2) (%)</b>	<b>Variance: <math>\frac{ max - min }{max}</math> (%)</b>
<b>Modulation Depth</b>	0,9796	0,0010	0,21%	0,30%
<b>Calculated SVM</b>	1,0081	0,0004	0,08%	0,12%


# Stability of some LED lamps




SVM Stability




SVM Stability



PstLM Stability




PstLM Stability





# Stability and repeatability of $P_{st}^{LM}$ and SVM of some LED lamps




LED lamps operated at 60 Hz AC power, sampled at 50 kHz, sampling time 60 S, measured at every 5 min. from cold start.





Stability






Repeatability





Stability





Repeatability



Stability



Repeatability





---

# Outreach activities

# Recent Conferences, Workshops

---

- Oct 2022: CIE Tutorial and Expert Symposium on Measurement of TLM (Athens, Greece)
  1. IEA 4E SSL Annex Interlaboratory Comparison of Measurements of Temporal Light Modulation – Plan (Coyne, S. and Ohno, Y.)
  2. Minimising the Uncertainties in the Calculation of Stroboscopic Effect Visibility Measure (Dam-Hansen, C., Coyne, S., Isoardi, G., Ohno, Y.)
- Nov 2022: COARM/CIE USANC Annual Join Conference
  1. TLM Measurements for Characterizing the Standardized Measures for Visibility of Temporal Light Artefacts (Li, Jiaye., Ohno, Y.)
- Feb 2023: CIE Australia Lighting Research Conference (Sydney, Australia)
  1. Measurement of Temporal Light Modulation: Improving Calculation Methods for Stroboscopic Effect Visibility Measure (Coyne, S., Isoardi, G.)



---

# Timeline for IC 2022

# Planned Schedule of IC 2022

Year 2022	Year 2023				Year 2024
Sep – Dec	Jan – March	April – June	July – Sep	Oct – Dec	Jan – Aug
<b>Nucleus labs intercomparison</b>					
Nucleus labs identified. Test protocol agreed & artefacts prepared	Nucleus labs (Operational & Supporting) intercomparison	Prepare artefacts for IC 2022	Coordinate IC 2022 laboratories		
<b>Expert Panel &amp; Management Committee</b>					
1) Experts assessment of nucleus lab IC outcomes 2) MC decision on IC2022		Public call for IC 2022			
<b>Participant Laboratories</b>					
			Laboratories participate in IC 2022		
<b>IC 2022 Task Leaders</b>					
Report on Nucleus Laboratory Comparison results			Data analyses and Individual Test Reports		Final Report on IC 2022